Lesley Keal

From: planning@hinckley-bosworth.gov.uk
Posted At: 05 July 2010 11:39
Conversation: ConsulteeAccess for Planning - Application Comments (10/00480/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (10/00480/FUL)

ConsulteeAccess for Planning - Application Comments (10/00480/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

ConsulteeAccess for Planning - Application Comments for 10/00480/FUL "Chris Brown" you have been sent this email because you or somebody else has submitted a comment on a Planning Application to the planning department using your email address.
A summary of your comments is provided below.
Comments were submitted at 05/07/2010 11:38:53 from chris.brown@hinckley-bosworth.gov.uk
Application Summary

Application Number: 10/00480/FUL
Address:
93 Arnolds Crescent
Newbold Verdon
Leicester
Leicestershire
LE9 9LW
Proposal:
EXTENSIONS AND ALTERATIONS TO DWELLING
Case Officer:
Kevin Roeton
Customer Details

Name:
Chris Brown
Address:
empty
Comments:
The public foul/combined sewer passing the front wall of the dwelling may be closer to the building than shown on the plan. As a precaution (unless the applicant has already verified the track of the sewer) the pipe should be located electronically or by trial excavation.

Properties in the immediate locality are vulnerable to flooding by both sewage and surface water.
ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.