
From: Pete Reid
Sent: 25 June 2025 11:24
To: Planning Folder New
Subject: RE: Planning Application Consultation for HBBC Drainage ref 25/00431/P3CR

Categories: Yasmin

Please input as unable to submit consultee comments on planning portal:

Advice to Applicant:

According to the Environment Agency (EA) website, the application site is located within Flood Zone 1, designated as low probability of flooding from rivers and sea, and the principle of development in low flood risk areas is acceptable. The EA Surface Water mapping also indicates that the application site is located in an area at very low risk of flooding from surface water.

The surface water drainage system for the proposed development should incorporate sustainable drainage principles (SuDS) to mitigate the risk of flooding on the site, and ensure that surface water runoff does not increase flood risk elsewhere. The proposals should also include measures to address issues of water quality in accordance with current SuDS guidance.

The proposed outfall for the discharge of surface water runoff from the development should be in accordance with the hierarchical approach outlined in Building Regulations Part H.

The use of infiltration drainage is preferred, subject to the site being free from a contaminated ground legacy. The suitability of the ground strata for soakaway drainage should be ascertained by means of the test described in BRE Digest 365, and the results approved by the Building Control Surveyor before development is commenced

If the ground strata are insufficiently permeable to avoid discharging some surface water off-site, flow attenuation methods should be employed, either alone or in combination with infiltration systems and/or rainwater harvesting systems.

Pete Reid
Drainage Consultant
Hinckley and Bosworth Borough Council

Email: pete.reid@hinckley-bosworth.gov.uk
Phone: 01455 255722

Hinckley & Bosworth Borough Council, Hinckley Hub, Rugby Rd, Hinckley, Leics LE10 0FR

-----Original Message-----

From: planning@hinckley-bosworth.gov.uk <planning@hinckley-bosworth.gov.uk>
Sent: 04 June 2025 10:32
To: Pete Reid <Pete.Reid@hinckley-bosworth.gov.uk>
Subject: Planning Application Consultation for HBBC Drainage ref 25/00431/P3CR

Please see attached consultation document from Hinckley & Bosworth Borough Council.

Any opinions expressed in this message are those of the sender and do not necessarily express the views of the Borough Council. The information contained in this message, and any attachments, is intended solely for the use of the individual or organisation to whom this message is sent, and should be treated as private and confidential. If you have received this email in error, please notify Hinckley and Bosworth Borough Council (ICT Services): Tel: +44 (01455) 238141.