
From: public.access@hinckley-bosworth.gov.uk
Sent: 10 April 2025 17:27
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 25/00277/CLP

Categories: Karen

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 10/04/2025 5:26 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	25/00277/CLP
Address:	Barton Hill Fields Farm Main Street Barton In The Beans Nuneaton Leicestershire CV13 0DJ
Proposal:	Erection of outbuilding
Case Officer:	Matt Jedruch

[Click for further information](#)

Comments Details

Note to Applicant:

Comments:	Rainwater from the outbuilding roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, and not be permitted to discharge directly onto the surface of the application site and neighbouring properties.
-----------	---

Kind regards